Verification No.: CLJS22070539642R

VERIFICATION OF LVD COMPLIANCE

Applicant:	Projoy Electric Co., Ltd.
Address of applicant:	No. 2266, Taiyang Road, Xiangcheng District, Suzhou, China
Manufacturer:	Jiangsu Projoy Electric Co., LTD. No. 2266, Taiyang Road, Xiangcheng District, Suzhou, China
Product Description:	Leakage Protector
Model No.:	PEL1-63
Rating:	Rated current: 16/20/25/32/40/50/63A optional; leakage current 10/30/100/300mA optional; AC voltage 240V/415V optional; leakage protection type: A/B/AC optional

Sufficient samples of the product have been tested and found to be in conformity with

Test Standard:	EN 61008-1:2012+A12:2017
As shown in the Test Report Number(s):	TLJS22070539642R
Date of issue:	July 07th, 2022
Date of expiry:	July 06th, 2027

Conclusion

This Verification of LVD Compliance has been granted to the applicant based on the results of the TCF, performed by Global Testing Services Co., Ltd. on the sample of the above-mentioned product in accordance with the provisions of the relevant specific standards and the Directive 2014/35/EU. The CE mark as shown below can be used, under the responsibility of the manufacturer, after completion of an EU Declaration of Conformity and compliance with all relevant EU Directives. The affixing of the CE marking presumes in addition that the conditions in annexes III and IV of the Directive are fulfilled.

Approved by: Hermann Weiher

For and on behalf of
Global Testing Services Co., Ltd

CE

GLOBAL TESTING SERVICES CO., LTD. GTS CERTIFICATION

Global Testing Services Co., Ltd
E-mail:info@gts-lab.com http://www.gts-lab.com
Floor 2nd, Building D-1, No. 128, Shenfu Road, Minhang District, Shanghai, China.

Copyright of this certificate is owned by Global Testing Services Co., Ltd and may not be reproduced other than in full and with the prior approval of the General Manager.

ZERTIFIKAT ■ CERTIFICATE ■ CERTIFNΦNKAT ■ CERTIFICADO ■ CERTIFICAT