Certificate of compliance

Applicant:	**NingBo Deye Inverter Technology Co., Ltd.** No. 26 South YongJiang Road, Daqi, Beilun, NingBo **China**
Product:	**Photovoltaic (PV) inverter**
Model:	**SUN-18K-G05, SUN-20K-G05,** **SUN-22K-G05, SUN-23K-G05, SUN-25K-G05**

The device is designed to work as a generation unit of the type: A

Inverter for three-phase parallel connection to the public grid. The network monitoring and disconnection device is an integral part of the above-mentioned model.

Applied rules and standards:

EN 50549-1:2019
Requirements for parallel connection of installations with distribution networks - Part 1: Connection to an LV distribution network - Production of installations up to and including Type B

4.4 Normal operating range
4.5 Immunity to disturbances
4.6 Active response to frequency deviation
4.7 Power response to voltage variations and voltage changes
4.8 EMC and power quality
4.9 Interface protection
4.10 Connection and starting to generate electrical power
4.11 Ceasing and reduction of active power on set point
4.13 Requirements regarding single fault tolerance of interface protection system and interface switch

EN 50549-10:2022
Requirements for generating plants to be connected in parallel with distribution networks - Part 10: Tests for conformity assessment of generating units

Commission Regulation (EU) 2016/631 of 14 April 2016
Establishing a network code on requirements for grid connection of generators (NC RFG).
Type approval for generation units to use in Type A

At the time of issue of this certificate, the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number:	**ASUE-ESH-P24012011**	**Certification Program:**	**NSOP-0032-DEU-ZE-V01**
Certificate number:	**U24-0500**	**Date of issue:**	**2024-06-10**

Certification body

Domenik Koll
Head of Energy Systems

DAkkS Deutsche Akkreditierungsstelle D-ZE-12024-01-00

Certification body Bureau Veritas Consumer Products Services Germany GmbH accreditation to DIN EN ISO/IEC 17065

Testing laboratory accredited according to DIN EN ISO/IEC 17025

A partial representation of the certificate requires the written approval of Bureau Veritas Consumer Products Services Germany GmbH

Annex to the EN 50549-1 certificate of compliance No. U24-0500

Appendix

Extract from test report according to EN 50549-1 **No. ASUE-ESH-P24012011**

Type Approval and declaration of compliance with the requirements of EN 50549-1 and Commission Regulation (EU) 2016/631 of 14 April 2016				
Manufacturer / applicant	**NingBo Deye Inverter Technology Co., Ltd.** No. 26 South YongJiang Road, Daqi, Beilun, NingBo **China**			
Micro-generator Type	Photovoltaic inverter			
	SUN-18K-G05	**SUN-20K-G05**	**SUN-22K-G05**	**SUN-23K-G05**
Photovoltaic (DC)				
MPP DC voltage range [V]	200-1000	200-1000	200-1000	200-1000
Max DC voltage [V]	1100	1100	1100	1100
Max. input DC current [A]	2*26	2*26	2*26	2*26
Connection (AC)				
Output AC voltage [V]	3L/N/PE, 230/400, 50/60Hz	3L/N/PE, 230/400, 50/60Hz	3L/N/PE, 230/400, 50/60Hz	3L/N/PE, 230/400, 50/60Hz
Max AC current [A]	28,7	31,9	35,1	36,7
Active Power [kW]	18	20	22	23
Max. apparent power [kVA]	19,8	22	24,2	25,3
	SUN-25K-G05	--	--	--
Photovoltaic (DC)				
MPP DC voltage range [V]	200-1000	--	--	--
Max DC voltage [V]	1100	--	--	--
Max. input DC current [A]	2*26	--	--	--
Connection (AC)				
Output AC voltage [V]	3L/N/PE, 230/400, 50/60Hz	--	--	--
Max AC current [A]	39,8	--	--	--
Active Power [kW]	25	--	--	--
Max. apparent power [kVA]	27,5	--	--	--
Firmware version	5512-0326			
Description of the structure of the power generation unit: The power generation unit is equipped with a DC and line-side EMC filter. The power generation unit has no galvanic isolation between DC input and AC output. Output switch-off is performed with single-fault tolerance based on the inverter bridge and two series-connected relays in each line and neutral. This enables a safe disconnection of the power generation unit from the network in case of error.				

Annex to the EN 50549-1 certificate of compliance No. U24-0500

Appendix

Extract from test report according to EN 50549-1 **No. ASUE-ESH-P24012011**

Note:

The settings of the interface protection are password protected adjustable.

In case the above stated generators are used with an external protection device, the protection settings of the inverters are to be adjusted according to the manufacturer's declaration.

The above stated generators are tested according to the requirements in the EN 50549-1:2019 Commission Regulation (EU) 2016/631 of 14 April 2016. Any modification that affects the stated tests must be named by the manufacturer/supplier of the product to ensure that the product meets all requirements.