

Certificate of compliance

Applicant: NingBo Deye Inverter Technology Co., Ltd.
No. 26 South YongJiang Road Daqi Beilun NingBo
China

Product: Hybrid inverter

Model: SUN-5K-SG01HP3-EU-DM2, SUN-6K-SG01HP3-EU-DM2,
SUN-8K-SG01HP3-EU-DM2, SUN-10K-SG01HP3-EU-DM2,
SUN-12K-SG01HP3-EU-DM2

The device is designed to work as a generation unit of the type: **A**

Inverter for three-phase parallel connection to the public grid. The network monitoring and disconnection device is an integral part of the above-mentioned model.

Applied rules and standards:

EN 50549-1:2019/A1:2023

Requirements for parallel connection of installations with distribution networks - Part 1: Connection to an LV distribution network - Production of installations up to and including Type B

- 4.4 Normal operating range
- 4.5 Immunity to disturbances
- 4.6 Active response to frequency deviation
- 4.7 Power response to voltage variations and voltage changes
- 4.8 EMC and power quality
- 4.9 Interface protection
- 4.10 Connection and starting to generate electrical power
- 4.11 Ceasing and reduction of active power on set point
- 4.13 Requirements regarding single fault tolerance of interface protection system and interface switch

EN 50549-10:2022

Requirements for generating plants to be connected in parallel with distribution networks - Part 10: Tests for conformity assessment of generating units

Commission Regulation (EU) 2016/631 of 14 April 2016

Establishing a network code on requirements for grid connection of generators (NC RFG).
Type approval for generation units to use in Type A plants.

At the time of issue of this certificate, the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number: ASUE-ESH-P25050525

Certificate number: U25-0860

Certification Program: NSOP-0032-DEU-ZE-V10

Date of issue: 2025-10-02

Accreditation



Certification body

Domenik Koll
Head of Energy Systems Germany



Type Approval and declaration of compliance with the requirements of EN 50549-1 and Commission Regulation (EU) 2016/631 of 14 April 2016

Manufacturer	NingBo Deye Inverter Technology Co., Ltd. No. 26 South YongJiang Road Daqi Beilun NingBo China			
Product type	Hybrid inverter			
Static converter model	SUN-5K-SG01HP3-EU-DM2	SUN-6K-SG01HP3-EU-DM2	SUN-8K-SG01HP3-EU-DM2	SUN-10K-SG01HP3-EU-DM2
Input DC (photovoltaic)				
MPP voltage range [V]	150-850	150-850	150-850	150-850
Max. input voltage [V]	1000	1000	1000	1000
Max. input current per MPPT [A]	18+18	18+18	18+18	18+18
Input DC (battery)				
DC voltage range [V]	160-700	160-700	160-700	160-700
Max. DC voltage [V]	700	700	700	700
Max. DC current per DC input [A]	37	37	37	37
Output AC				
Rated AC voltage [V]	3L/N/PE, 230/400V, 50Hz	3L/N/PE, 230/400V, 50Hz	3L/N/PE, 230/400V, 50Hz	3L/N/PE, 230/400V, 50Hz
Rated output current [A]	7,3	8,7	11,6	14,5
Max. output current [A]	8,0	9,6	12,8	16,0
Nom. converter output (P _{NINV}) [W]	5000	6000	8000	10000
Max. apparent power [VA]	5500	6600	8800	11000
Static converter model	SUN-12K-SG01HP3-EU-DM2	--	--	--
Input DC (photovoltaic)				
MPP voltage range [V]	150-850	--	--	--
Max. input voltage [V]	1000	--	--	--
Max. input current per MPPT [A]	18+18	--	--	--
Input DC (battery)				
DC voltage range [V]	160-700	--	--	--
Max. DC voltage [V]	700	--	--	--
Max. DC current per DC input [A]	37	--	--	--
Output AC				
Rated AC voltage [V]	3L/N/PE, 230/400V, 50Hz	--	--	--
Rated output current [A]	17,4	--	--	--
Max. output current [A]	19,2	--	--	--
Nom. converter output (P _{NINV}) [W]	12000	--	--	--
Max. apparent power [VA]	13200	--	--	--

Interface protection system and interface switch (Network and system protection “NS-protection”)	
Type of protection	Integrated NS-protection
Assigned to generation unit type	SUN-5K-SG01HP3-EU-DM2, SUN-6K-SG01HP3-EU-DM2, SUN-8K-SG01HP3-EU-DM2, SUN-10K-SG01HP3-EU-DM2, SUN-12K-SG01HP3-EU-DM2
Integrated interface switch	Type of switching equipment 1: Relay (Model CHFN-V-112H1A2F) Type of switching equipment 2: Relay (Model CHFN-V-112H1A2F)
	Note: The output is switched off by the inverter bridge and two relays in series in each line and neutral.
Firmware version	1082
Note <p>The settings of the interface protection are password protected adjustable.</p> <p>In case the above stated generators are used with an external protection device, the protection settings of the inverters are to be adjusted according to the manufacturer's declaration.</p> <p>The above stated generators are tested according to the requirements in the EN 50549-1:2019 Commission Regulation (EU) 2016/631 of 14 April 2016. Any modification that affects the stated tests must be named by the manufacturer/supplier of the product to ensure that the product meets all requirements.</p>	